

Agency Information

This certificate is only used for web browsing, proving that the SETsafe | SETfuse product has been certified.

For the full version, please contact: sales@SETfuse.com

Thank you for your support.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010308686288

NAME AND ADDRESS OF THE APPLICANT

Xiamen 'SET Electronics Co.,ltd

No. 8067 West Xiang'an Road Torch High-Tech Industrial District Xiang'an Xiamen Fujian Province P.
R. China

NAME AND ADDRESS OF THE MANUFACTURER

Xiamen 'SET Electronics Co.,ltd

No. 8067 West Xiang'an Road Torch High-Tech Industrial District Xiang'an Xiamen Fujian Province P.
R. China

NAME AND LOCATION OF THE FACTORY

Xiamen 'SET Electronics Co.,ltd

No. 8001 West Xiang'an Road, Torch High-Tech Industrial District, Xiang'an, Xiamen, Fujian Province,
361101, P. R. China

PRODUCT NAME,MODEL AND SPECIFICATION

LV Fuse

LFR01; Un: DC1000V(50A~400A)、DC800V(450A); In: 50A、63A、80A、100A、125A、
160A、200A、250A、315A、350A、400A、450A; Ii: 50kA; aR; See the Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Sep.10,2024

Valid until: Sep.09,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation


CERTIFICATE NO. : 2024010308686288

Appendix: Page 1 of 1

Type explanation

LFR 01 - □ □ - □
(1) (2) (3) (4) (5)

- (1) 快速熔断器
- (2) 内部尺码代号
- (3) 额定电流: 50A、63A、80A、100A、125A、160A、200A、250A、315A、350A、400A、450A
- (4) 额定电压: 10: DC1000V; 08: DC800V
- (5) 安装方式代码: BB: B型螺栓连接---DIN;
FB: C型螺栓连接---北美;
BT: A型螺栓连接---英国;
FE: A型接触片式连接;



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.